



SECTION A-A

NOTES:

1. ANCHOR BLOCKS SHALL BE INSTALLED WHERE THE PIPE GRADE IS 1 IN 10 MAXIMUM OR STEEPER. MAXIMUM SPACING OF ANCHOR BLOCKS SHALL BE 10 METRES.
2. THE BARREL OF UPVC PIPES SHALL HAVE GRIT APPLIED AT EACH ANCHOR BLOCK LOCATION TO ENSURE PROPER ADHESION OF THE CONCRETE TO THE PLASTIC PIPE.
3. ANCHOR BLOCKS SHOULD BE LOCATED IMMEDIATELY DOWNSTREAM OF THE PIPE COLLAR TO ENSURE MAXIMUM PIPE RESTRAINT.

CHECKED

*[Signature]*

APPROVED

*[Signature]*

SCALE

N.T.S.

KNOX CITY COUNCIL

ANCHOR BLOCK

DATE

30-08-2012

REVISION

B

CAD FILE NAME

S 170.1